



Badger Bob's Plumbing  
 215 Interstate Blvd  
 Sarasota, FL 34240  
 CAC1815977 - CFC1426265  
 941-924-1920 or 941-341-4280  
 Service...it's Who We Are!

Invoice 28478  
 Invoice Date 3/30/2017  
 Completed Date 3/30/2017  
 Technician Chris Coakley  
 Customer PO

**Billing Address**  
 TROPICAL SANDS REMAX  
 5116 OCEAN BLVD  
 SARASOTA, FL 34242 USA

*SR ASSOC.*

**Job Address**  
 MAIN BUILDING - SUNSET  
 ROYALE  
 711 Beach Road #MAIN  
 BUILDING  
 Siesta Key, FL 34242 USA

**Description of Work**

I was out in November of 2016 to test the water pressure for the building. At that time the pressure before it passed through the backflow was approximately 70 psi. It was approximately 64-65 psi as it passed through the backflow. I checked the pressure at the hose bib next to the walkway and I had approximately 60 psi. Today I checked the pressure at the backflow and it was 60 psi. I checked the pressure at the outletside of the backflow and I had approximately 54-55 psi. Generally there is a drop of 3-7 psi as it passes through the backflow. Next I checked the pressure at the hose bib next to the walkway and I have 50 psi. Next we went floor to floor to monitor the pressure. In unit 408 I checked the pressure at the tankless W/H and I got a reading of approximately 38 psi. That is only a drop of 22 psi from the inlet of the backflow to the 4th floor. Generally it takes 1 psi to push water 2.5'. Originally the building was plumbed with 1" risers to feed each unit on each floor. Since then the building has been retrofitted with 2" risers. Since we are currently in peak season and the demand for water throughout the Key is at its highest, the fact that there is only a 10 psi difference from off season to now is not a cause for concern. I don't see the necessity to instal any form of any booster system.

Task #	Description	Quantity	Your Price	Your Total
PLMR110	Labor time associated with project today.	1.00	\$125.00	\$125.00
<b>Sub-Total</b>				\$125.00
<b>Tax</b>				\$0.00
<b>Total Due</b>				\$125.00

Our Guarantee: This invoice displays charges for this repair project only. We guarantee only the parts installed by us will perform as designed under conditions of normal usage for the following periods.  
 Appliance Repair: 90 days for the part and 30 days on the labor. No warranty on Freon, glass, or plastic parts.  
 Air Conditioning Repair: 1 year on the parts and labor.  
 Plumbing: 90 days on parts and labor for standard repairs. Drain line clearing is 30 days. New water heater installs are 1 year parts and labor.  
 Should you ever have a concern or question regarding our work, please feel free to contact us at your earliest convenience.

PAYMENT, UP TO A LIMITED AMOUNT, MAY BE AVAILABLE FROM THE FLORIDA HOMEOWNERS' CONSTRUCTION RECOVERY FUND IF YOU LOSE MONEY ON A PROJECT PERFORMED UNDER CONTRACT, WHERE THE LOSS RESULTS FROM SPECIFIED VIOLATIONS OF FLORIDA LAW BY A LICENSED CONTRACTOR. FOR INFORMATION ABOUT THE RECOVERY FUND AND FILING A CLAIM, CONTACT THE FLORIDA CONSTRUCTION INDUSTRY LICENSING BOARD AT THE FOLLOWING TELEPHONE NUMBER AND ADDRESS: 2601 Blair Stone Road . Tallahassee, Florida 32399 Phone: 850-487-1395

I understand and authorize the services as they have been explained to me. I understand that I will be charged the estimated price upon completion. Please move forward with the repair.

I hereby accept the above performed service, and charges, as being satisfactory and acknowledge the equipment has been left in good working condition. I understand that payment is due at the time services are rendered and a 2% late fee will be applied every 30 days thereafter if the balance of this invoice is not paid in full.  
 \*PLEASE MAKE ALL CHECKS PAYABLE TO: BB PLUMBING or BADGER BOB'S PLUMBING Thank you!